







Energy Efficiency Guidelines for Office Buildings in Tropical Climate


Summary Session 28th February 2013





- Develop Energy Efficiency Guidelines for Office Buildings in Tropical climates:
 - Task1: Technical Review
 - Task 2: Baseline Design
 - Task 3: Energy Consumption assessment
 - Task 4: Baseline Design Cost assessment
 - Task 5: Energy Efficiency Design
 - Task 6: Simulation of the Energy Balance
 - Task 7: Savings assessment
 - Task 8: Cost Assessment
 - Task 9: Design Guide Book


Methodology




Technical Review

- Reviewed technical documents
 - Florida Building Code 2010
 - Energy Conservacion
 - Mechanical
 - International Energy Conservation Code 2012
 - RESET, Costa Rica, 2012
 - Casa Azul, Brasil 2010
 - Green Building Index, Malaysia, 2009
- Reviewed Guide Books
 - Casa Ausente. Diseñar, construir y vivir en una casa ecológica, Arq. Fernando Abruña
 - Climate Responsive design, Richard Hyde
 - Eficiencia energéticana arquitectura, Roberto Lamberts, Luciano Dutra, Fernando O.R. Pereira
 - A green Vitruvius, principles and practice of sustainable architectural design

- Baseline Design-> Energy Simulation
 - Halls of Justice Project drawings
 - Other: technical codes etc.
 - (standardize drawings)
 - Two sizes: Small (3000 m2) and Medium (6000 m2)

















Energy Efficiency Design-> Energy Simulation

- Parametric Study
 - Shape of the building
 - Insulation and thermal mass
 - Glazing type and amount of glazing
 - Building Orientation
 - Solar protection window glazing elements
 - Roof
 - Contact between building and ground
 - Night natural ventilation
 - Heat recovery device in ventilation system














Summary of Parametric Study

Strong impact


Amount of glazing

Heat recovery device in ventilation system Solar protection – window glazing elements Shape of the building Roof **Building Orientation** Glazing type Night natural ventilation Contact between building and


Weak impact


ground

Insulation and thermal mass



Energy Efficient Design







				Total	Total	
	Cooling		Cooling	(light.+cool./	(ligth.+cool	
Models	Lighting	(electricity)	(thermal)	elect.)	/therm)	Improvement
	kWh/m2	kWh/m2	kWh/m2	kWh/m2	kWh/m2	
Baseline*(BD)	54,0	128,2	320,5	182,2	374,5	Ref (0%)
Baseline**(BD)	37,9	128,2	320,5	358,4	358,4	Ref (0%)
Energy Efficient B. (EED)**	54,0	111,7	279,3	165,7	333,3	9,1%
EED**+TR	54,0	93,7	234,2	147,7	288,2	19,0%
EED+TR+LC	31,3	81,3	203,2	112,6	234,5	38,2%
EED+TR+LL	20,3	76,6	191,4	96,8	211,7	46,9%
EED+TR+LL+LC	11,7	71,7	179,3	83,4	191,0	54,2%
EED+TR+LL+LC+PV	11,7	71,7	179,3	17,9	191,0	90,2%
EED+TR+LL+LC+PV+ST	11,7	71,7	179,3	16,5	191,0	90,9%

*without light control ** with light control (LC)


EEB: Energy Efficient Building

TR: Thermal recovery LC: Lighting Control LL: LED lighting

PV: Phtovoltaics ST: Solar Thermal

COP: 2,5

Life Cycle Cost:



Net Present Value




- Internal Return Rate
- Savings to Investment Ratio






Desired outputs; needed inputs



Costs of Measures

	Type of Solution	Solution	Type Baseline	Base Cost	Starting Date	Type of Cost	Recurrence	Net Present Value	Salvage Value	Number Installments	Duration (Years)
#1											
#2											
#3											
#4											
#5											
#6											
#7											
#8											

Comparison of EED Measures




Type of solution	Design Concept Thermal Insulation	NPV of all costs	Consump tion (kVh
Baseline	TI-A001 M025	\$54.225	414.259
Efficiency Solution	TI-A025 M025	\$57.181	408.012
	Difference	36.331	-6.247



	Cost		Inter est	Lend	NPV Electricity Savings			Net Present Value (NPV) Savings				Internal Rate of Return (IRR)			Savings to Investment Ratio (SIR)					
Power Utility	kWh	Year		Rate	Min	Ref	Mas		Min	Ref		Mar	Min	Ref	Mas	A	tin	R	ef j	Mar
Antigua (APUA)	\$0,38	2011	6,5%	10,9%	\$35.912	\$41,351	\$59,457		-\$419	\$5.02	0 🔵	\$23,126	9 5,9%	0 10,0%	9,2%		1,0	0	1,1 🔍	1,6
Bahamas (GB Power)	\$0,17	2012	4,0%	5,1%	\$15.593	\$17.955	\$25.817		-\$20.738	-\$18.37	6 🔘	-\$10.514	18%	2.1%	0 10,7%		0,4		0,5 🔘	0,7
Bahamas (BEC)	\$0,33	2008	4,0%	5,1%	\$31.187	\$35.910	\$51.634		-\$5.144	-\$42	21 🔍	\$15,303	O 4,4%	8.5%	17,6%		0,9		1,0 🔘	1,4
Barbados (BL&P)	\$0,38	2011	7,0%	8,7%	\$35.912	\$41.351	\$59,457		-\$419	\$5.02	0 🔵	\$23,126	5,9%	0 10,0%	9,2%		1,0	0	1,1 🔍	1,6
Dominica (DOMLEC)	\$0,39	2010	6,5%	8,9%	\$36.857	\$42,439	\$61.022	0	\$526	\$6.10	8 🔵	\$24,691	6.2%	0 10,3%	9,5%	0	1,0	0	1,2 🔵	1,7
Grenada (GRENLEC)	\$0,39	2011	6,5%	10,7%	\$36.857	\$42,439	\$61.022	0	\$526	\$6.10	8 🔵	\$24,691	6,2%	0 10,3%	9,5%	0	1,0	0	1,2 🔍	1,7
Montserrat (MUL)	\$0,40	2009	6,5%	8,6%	\$37.802	\$43.528	\$62.587		\$1.471	\$7.19	6 🔵	\$26,255	6,5%	0 10,6%	9,8%	0	1,0	0	1,2 🔍	1,7
Nevis (NEVLEC)	\$0,31	2010	6,5%	9,2%	\$29.297	\$33,734	\$48,505		-\$7.035	-\$2.59	7 🔍	\$12,173	3,8%	O 7.9%	16,9%		0,8		0,9 🜕	1,3
St. Kitts Elec. Dep.	\$0,29	2011	6,5%	9,2%	\$27.407	\$31.558	\$45,375		-\$8.925	-\$4.77	4 🔘	\$9.044	3,1%	07.2%	16,2%		0,8		0,9 🜕	1,2
St. Lucia (LUCELEC)	\$0,32	2010	6,5%	10,2%	\$30.242	\$34.822	\$50,069		-\$6.090 @	-\$1.50	9 🔘	\$13,738	4.1%	082%	17,2%		0,8		1,0 🔘	1,4
ST. Vincent (VINLEC)	\$0,32	2010	6,5%	9,1%	\$30.242	\$34.822	\$50,069		-\$6.090	-\$1.50	9 🔘	\$13,738	4.1%	0 8,2%	17,2%		0,8	0	1,0 🔘	1,4
Average	***		6,1%	8,7%	\$31.573	\$36.355	\$52.274		-\$4.758	\$2	1 0	\$15.943	04.4%	08.5%	0 17,5%	0	0,9	0	1,0 🤎	1,4


Interpretation of results:




	Net Present Value (NPV) Savings										
Power Utility		Min		Ref	Max						
Antigua (APUA)		\$5,912	0	\$11,351	0	\$29,457					
Bahamas (GB Power)	0	-\$14,407	0	-\$12,045	0	-\$4,183					
Bahamas (BEC)		\$1,187	0	\$5,910	0	\$21,634					
Barbados (BL&P)		\$5,912	0	\$11,351	0	\$29,457					
Dominica (DOMLEC)		\$6,857	0	\$12,439	0	\$31,022					
Grenada (GRENLEC)		\$6,857	0	\$12,439	0	\$31,022					
Montserrat (MUL)	0	\$7,802	0	\$13,528	0	\$32,587					
Nevis (NEVLEC)	0	-\$703	0	\$3,734	0	\$18,505					
St. Kitts Elec. Dep.	0	-\$2,593	0	\$1,558	0	\$15,375					
St. Lucia (LUCELEC)	0	\$242	0	\$4,822	0	\$20,069					
ST. Vincent (VINLEC)	0	\$242	0	\$4,822	0	\$20,069					
Average	0	\$1,573	0	\$6,355	0	\$22,274					

LCC tool

1. Baseline Building vs. Energy Efficient Building LCC




- LCC tool
 - 2. Choose between design alternatives considering LCC



Draft of the Guide Book

Form factor/compactness

- The shape of the building has an impact on the energy demand
- Shapes more similar to "Long bar" rather than "Tower"



Glazed surface

 Window glazing over façade surface (window-to-wall ratio): low values

Glazing types

 An improved glazing quality reduces the energy demand for cooling the building

Orientation

- In the case of a building with long and short façades the improvement of energy performance depends strongly on the adequate orientation
- Best results when largest façades oriented South and
 North minimize the surfaces oriented East and West
- Consider the dominant wind direction at the location

Solar protection

Strong influence on cooling demand while relative increase in lighting demand

Roof design

- Roof surface receives highest solar radiation
- It is recommended to provide shading to roof + ventilation

Ground contact

 The results of the simulations do not show big differences; the best option would be keeping the contact with the ground without any thermal insulation

Night ventilation

- Limited to the dry period of the year.
- Renovations and thermal mass adjusted

Daylighting

- South and North orientation of the largest façades.
- Not excessive depth
- Homogeneous distribution of glazing around 20% of the façade surface.
- Fixed protections complemented with mobile protections



Ventilation heat recovery

 heat is exchanged between the external, hot and humid air and the inside, exhaust air

Efficient lighting

 LED: effect in whole energy demand is double, as not only this means a reduction in demand for lighting, but also a reduction in heat gains from lighting and thus a lower demand for cooling

Lighting control

 Motion control or control of artificial lighting depending on the amount of daylight can decrease overall energy demand

HVAC equipment

- efficient chillers that can work in the most usual conditions of local climate; possibility of modulating power depending upon demand (inverter).
- if local conditions allow, possibility to combine with "free cooling"
- Distribution of cooling at moderate temperatures; prefer radiant solutions to very low temperature air distribution.
- High degree of zoning.
- Control: possibility to turn off emitters if open windows are detected or in moments of no occupancy.

Photovoltaics

- Electricity generation
- Contribute to reduced cooling demand
- Also, rainwater harvesting

Solar thermal

 If the building has hot water demand (such as public buildings with kitchen /restaurant/ cafeteria/ toilets/ dressing rooms etc.) a solar thermal installation can provide part of such hot water demand.

Other recommendations

- Vegetation in the exterior of the building: medium of big size vegetation (e.g. trees) provide shading to walls and windows but also cool the ambient air through evapotranspiration.
- Buffer spaces: these zones, located between the external and internal spaces of the building, can provide: a decreased temperature difference, improved solar protection, can have vegetation, cool down external air temperature.
- Reducing infiltration and uncontrolled loss of conditioned air improving the building airtight
- Materials that enhance use of daylight (bright colors)
- specific demands are similar

Next suggested steps

- 1. Writing the final version of the Energy Efficiency Guidelines with recommendations for the design of new office buildings with energy efficiency criteria:
- architectural design
- passive solutions
- active in energy efficiency solutions
- integration of renewable energy in buildings
- 2. analysis of the Guide as a reference document for the building code in energy efficiency
- 3. adaptation of the guidelines to energy refurbishment of existing buildings
- 4. determine the mandatory energy efficiency measures for all new construction project (new or renovated buildings)
- 5. determine specific values of mandatory minimum efficiency (kWh/m2 year) for different types of buildings for energy demand linked to the design of the building and not to its activity
- 6. apply a common regulation in the interconnection to the grid of the power generation equipments with renewable sources, with net metering

Thank you

www.tta.com.es

Jaume Serrasolses: jaume.serrasolses@tta.com.es

Unai Arrieta: unai.arrieta@tta.com.es